

Serialized: 07/24/2019 06:42pmQC21

GARY GUARINO  
TOWNSHIP OF HOPEWELL  
201 WASHINGTON CROSSING-PENNINGTON ROAD  
TITUSVILLE, NJ 08560-1410

Regarding:  
STEVEN WILFING  
STONY BROOK ELEMENTARY SCHOOL  
20 STEPHENSON ROAD  
PENNINGTON, NJ 08534

**PROJECT ID:**

W01628 STONY BROOK

**LABORATORY REPORT NUMBER:**

L7124682



Authorized by: Douglas J. Gump  
Client Services Manager

TOWNSHIP OF HOPEWELL  
W01628 STONY BROOK  
STONY BROOK ELEMENTARY SCHOOL  
P.O. No:  
Inv. No: 1984485  
PWSID:

STEVEN WILFING  
STONY BROOK ELEMENTARY SCHOOL  
20 STEPHENSON ROAD  
PENNINGTON, NJ 08534

Regarding:  
STEVEN WILFING  
STONY BROOK ELEMENTARY SCHOOL  
20 STEPHENSON ROAD  
PENNINGTON, NJ 08534

## SAMPLE SUMMARY

Lab ID	Collected	Received	Matrix	Client ID
L7124682-1	06/17/19 09:00	06/17/19 13:05	WATER	KITCHEN SINK

Sample Description: **KITCHEN SINK**  
 Sample Number: **L7124682-1**  
 Matrix: **WATER**  
 Received Temp: **1.6 C**

Samp. Date/Time/Temp: **06/17/19 09:00am NA C**  
 Sampled by: **Suzanne E. Hughes, Eurofins QC, LLC**  
 Iced (Y/N): **Y**

## ENVIRONMENTAL MICROBIOLOGY -- KITCHEN SINK

Analytical Method: **SM 9223B** Run Date: **06/18/19 11:50AM** Workgroup:  
 Dilution: **1** Analyst: **RBK** File ID: **WM\_LOGBOOK\_SAT 96955 L7124682-1**  
 Units: Instrument: Basis:

Parameter	CAS	Result	MDL	RL*
Total Coliform, Coliort P/A	N/A	NEG	N/A	1
E. Coli, Coliort P/A	N/A	NEG	N/A	1

## FIELD SERVICES -- KITCHEN SINK

Analytical Method: **SM 2550B** Run Date: **06/17/19 09:00AM** Workgroup:  
 Dilution: Analyst: **SEH** File ID:  
 Units: **Deg. C** Instrument: Basis:

Parameter	CAS	Result	MDL	RL*
Field Temperature Celsius		20.9	N/A	0.5

Analytical Method: **SM 4500CL G** Run Date: **06/17/19 09:00AM** Workgroup:  
 Dilution: **1** Analyst: **SEH** File ID:  
 Units: **mg/l** Instrument: Basis:

Parameter	CAS	Result	MDL	RL*
Chlorine, residual	7782-50-5	ND	N/A	0.02

Analytical Method: **SM 4500H+B** Run Date: **06/17/19 09:00AM** Workgroup:  
 Dilution: **1** Analyst: **SEH** File ID:  
 Units: **units** Instrument: Basis:

Parameter	CAS	Result	MDL	RL*
pH, field		7.89	N/A	0.010

## --SUBCONTRACTED RESULT REFERENCES--KITCHEN SINK

See attached reports for the following Subcontract Laboratories:

Eurofins - Eaton Analytical, South Bend (EATONSB)  
 HALOACETIC ACIDS BY METHOD 552

Eurofins - Lancaster Laboratories, Environmental (ELLE)  
 ALKALINITY: to pH 4.5  
 CALCIUM  
 COPPER  
 EPA METHOD 524.2 THMS ONLY  
 LEAD  
 TOTAL DISSOLVED SOLIDS

\*=This limit was used in the evaluation of the final result.

PIN: 85365

Serial Number: 6530040

Sample Comments | Result Qualifiers:

L7124682-1 :

Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no Coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 col/100ml" or "NEG" for the Coliform Test. If your report indicates a positive result "POS" or a value of one (1) or greater, then your supply is "UNSAFE FOR DRINKING" contact your local Health Department.



\*=This limit was used in the evaluation of the final result.

PIN: 85365

Serial Number: 6530040

## DEFINITIONS

The following terms or abbreviations are used in this report:

Eurofins QC, LLC (EQC)

<	Less than: In conjunction with a numerical value, indicates a concentration less than RL / MDL
>	Greater than: In conjunction with a numerical value, indicates a concentration greater than RL / MDL
CFU	Colony Forming Unit
DF	Dilution Factor (For Microbiology, DF = volume of sample tested)
DRY	Result was reported on a dry weight basis
MCL	EPA recommended "Maximum Contaminant Level"
MDL	Method Detection Limit
MF	Membrane Filtration
MPN	Most Probable Number
ND	For odor test: No Odor Observed
ND	For all other tests: Analyte concentration Not Detected greater than the RL / MDL

NEG	Negative / Absent
NTU	Nephelometric Turbidity Units
POS	Positive / Present
PPB (µg/L)	Parts per billion: equivalent to 1 microgram per kilogram (µg/Kg) for solids or one microgram per liter (µg/L) for aqueous samples
PPM (mg/L)	Parts per million: equivalent to 1 milligram per kilogram (mg/Kg) for solids or one milligram per liter (mg/L) for aqueous samples
PRES	Presumptive
QUAL	Qualifier (Q)
RL	Laboratory Reporting Limit or Limit of Quantitation (LOQ)
TNTC	Too Numerous To Count
TON	Threshold Odor Number

### Data Qualifiers

J	Estimated value $\geq$ MDL, but $<$ RL
T	Temperature exceedance at receipt, refer to Sample Comments / Results Qualifiers section
E	Estimated CFU count (Microbiology)
Q	Qualifier defined in Sample Comment section on report

### Warranties, Terms, and Conditions

- Unless otherwise indicated in the Parameter field, analyses for environmental microbiology, odor, and pharmaceutical microbiology are performed at the EQC Horsham Facility (702 Electronic Dr. Horsham, PA 19044).
- Analyses for Field Parameters are performed by EQC Field staff. Locations and certifications are identified on the Chain of Custody as follows:
  - "ERF" = field staff performs tests under NJ State certification # 02015.
  - "VL" = field staff performs tests under NJ State certification # 06005.
  - "WG" = field staff performs tests under NJ State certification # PA001.
- Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.
- The report shall not be reproduced, except in full, without the written consent of the laboratory.
- All samples are collected as "grab" samples unless otherwise identified.
- Reported results relate only to the sample as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.
- EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance. EQC's internet program "LIVE ACCESS" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.
- The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry), Amanda Berd (Pharmaceutical Microbiology), and Jordan Thorngren (Water Microbiology).

### EQC Accreditations

Horsham Facility	NELAP/State IDs-	PA: 46-05499	NJ: PA093	NY: 12080	MD: 357
East Rutherford Facility	State ID-	NJ: 02015			
Vineland Facility	State ID-	NJ: 06005			
Wind Gap Facility	State ID-	NJ: PA001			

## LABORATORY REPORT

If you have any questions concerning this report, please do not hesitate to call us at (800) 332-4345 or (574) 233-4777.

*This report may not be reproduced, except in full, without written approval from EEA.*

## STATE CERTIFICATION LIST

State	Certification	State	Certification
Alabama	40700	Missouri	880
Alaska	IN00035	Montana	CERT0026
Arizona	AZ0432	Nebraska	NE-OS-05-04
Arkansas	IN00035	Nevada	IN00035
California	2920	New Hampshire*	2124
Colorado	IN00035	New Jersey*	IN598
Colorado Radiochemistry	IN00035	New Mexico	IN00035
Connecticut	PH-0132	New York*	11398
Delaware	IN035	North Carolina	18700
Florida*	E87775	North Dakota	R-035
Georgia	929	Ohio	87775
Hawaii	IN035	Oklahoma	D9508
Idaho	IN00035	Oregon (Primary AB)*	4074
Illinois*	200001	Pennsylvania*	68-00466
Illinois Microbiology	17767	Puerto Rico	IN00035
Illinois Radiochemistry	IN00035	Rhode Island	LAO00343
Indiana Chemistry	C-71-01	South Carolina	95005
Indiana Microbiology	M-76-07	South Dakota	IN00035
Iowa	098	Tennessee	TN02973
Kansas*	E-10233	Texas*	T104704187-18-12
Kentucky	90056	Texas/TCEQ	TX207
Louisiana*	LA014	Utah*	IN00035
Maine	IN00035	Vermont	VT-8775
Maryland	209	Virginia*	460275
Massachusetts	M-IN035	Washington	C837
Michigan	9926	West Virginia	9927 C
Minnesota*	018-999-338	Wisconsin	999766900
Mississippi	IN035	Wyoming	IN035
EPA	IN00035		

\*NELAP/TNI Recognized Accreditation Bodies

110 South Hill Street  
 South Bend, IN 46617  
 Tel: (574) 233-4777  
 Fax: (574) 233-8207  
 1 800 332 4345

## Laboratory Report

Client: QC Inc.

Attn: Nicki Smith  
 702 Electronic Drive  
 Horsham, PA 19044

Report: 456187  
 Priority: Standard Written  
 Status: Final  
 PWS ID: Not Supplied

Sample Information					
EEA ID #	Client ID	Method	Collected Date / Time	Collected By:	Received Date / Time
4332186	L7124682-1	552.2	06/17/19 09:00	Client	06/21/19 08:30

### Report Summary

Note: Sample container was provided by the client.

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Jim Vernon at (574) 233-4777.

*Note: This report may not be reproduced, except in full, without written approval from EEA. EEA is accredited by the National Environmental Laboratory Accreditation Program (NELAP).*


  
 \_\_\_\_\_  
 Authorized Signature Title

\_\_\_\_\_  
 06/28/2019  
 Date

Client Name: QC Inc.  
 Report #: 456187



Sampling Point: L7124682-1

PWS ID: Not Supplied

Disinfection Byproducts									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
631-64-1	Dibromoacetic acid	552.2	---	1.0	< 1.0	ug/L	06/25/19 08:24	06/26/19 11:57	4332186
79-43-6	Dichloroacetic acid	552.2	---	1.0	4.6	ug/L	06/25/19 08:24	06/26/19 11:57	4332186
79-08-3	Monobromoacetic acid	552.2	---	1.0	< 1.0	ug/L	06/25/19 08:24	06/26/19 11:57	4332186
79-11-8	Monochloroacetic acid	552.2	---	2.0	< 2.0	ug/L	06/25/19 08:24	06/26/19 11:57	4332186
76-03-9	Trichloroacetic acid	552.2	---	1.0	21	ug/L	06/25/19 08:24	06/26/19 11:57	4332186
---	Total HAA5	552.2	60 *	2.0	25.6	ug/L	06/25/19 08:24	06/26/19 11:57	4332186

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Reg Limit Type:	MCL	SMCL	AL
Symbol:	*	^	!

## Lab Definitions

**Continuing Calibration Check Standard (CCC) / Continuing Calibration Verification (CCV) / Initial Calibration Verification Standard (ICV) / Initial Performance Check (IPC)** - is a standard containing one or more of the target analytes that is prepared from the same standards used to calibrate the instrument. This standard is used to verify the calibration curve at the beginning of each analytical sequence, and may also be analyzed throughout and at the end of the sequence. The concentration of continuing standards may be varied, when prescribed by the reference method, so that the range of the calibration curve is verified on a regular basis. CCL, CCM, and CCH are the CCC standards at low, mid, and high concentration levels, respectively.

**Internal Standards (IS)** - are pure compounds with properties similar to the analytes of interest, which are added to field samples or extracts, calibration standards, and quality control standards at a known concentration. They are used to measure the relative responses of the analytes of interest and surrogates in the sample, calibration standard or quality control standard.

**Laboratory Duplicate (LD)** - is a field sample aliquot taken from the same sample container in the laboratory and analyzed separately using identical procedures. Analysis of laboratory duplicates provides a measure of the precision of the laboratory procedures.

**Laboratory Fortified Blank (LFB) / Laboratory Control Sample (LCS)** - is an aliquot of reagent water to which known concentrations of the analytes of interest are added. The LFB is analyzed exactly the same as the field samples. LFBs are used to determine whether the method is in control. FBL, FBM, and FBH are the LFB samples at low, mid, and high concentration levels, respectively.

**Laboratory Method Blank (LMB) / Laboratory Reagent Blank (LRB)** - is a sample of reagent water included in the sample batch analyzed in the same way as the associated field samples. The LMB is used to determine if method analytes or other background contamination have been introduced during the preparation or analytical procedure. The LMB is analyzed exactly the same as the field samples.

**Laboratory Trip Blank (LTB) / Field Reagent Blank (FRB)** - is a sample of laboratory reagent water placed in a sample container in the laboratory and treated as a field sample, including storage, preservation, and all analytical procedures. The FRB/LTB container follows the collection bottles to and from the collection site, but the FRB/LTB is not opened at any time during the trip. The FRB/LTB is primarily a travel blank used to verify that the samples were not contaminated during shipment.

**Matrix Spike Duplicate Sample (MSD) / Laboratory Fortified Sample Matrix Duplicate (LFSMD)** - is a sample aliquot taken from the same field sample source as the Matrix Spike Sample to which known quantities of the analytes of interest are added in the laboratory. The MSD is analyzed exactly the same as the field samples. Analysis of the MSD provides a measure of the precision of the laboratory procedures in a specific matrix. SDL, SDM, and SDH / LFSMDL, LFSMDM, and LFSMDH are the MSD or LFSMD at low, mid, and high concentration levels, respectively.

**Matrix Spike Sample (MS) / Laboratory Fortified Sample Matrix (LFSM)** - is a sample aliquot taken from field sample source to which known quantities of the analytes of interest are added in the laboratory. The MS is analyzed exactly the same as the field samples. The purpose is to demonstrate recovery of the analytes from a sample matrix to determine if the specific matrix contributes bias to the analytical results. MSL, MSM, and MSH / LFSML, LFSMM, and LFSMH are the MS or LFSM at low, mid, and high concentration levels, respectively.

**Quality Control Standard (QCS) / Second Source Calibration Verification (SSCV)** - is a solution containing known concentrations of the analytes of interest prepared from a source different from the source of the calibration standards. The solution is obtained from a second manufacturer or lot if the lot can be demonstrated by the manufacturer as prepared independently from other lots. The QCS sample is analyzed using the same procedures as field samples. The QCS is used as a check on the calibration standards used in the method on a routine basis.

**Reporting Limit Check (RLC) / Initial Calibration Check Standard (ICCS)** - is a procedural standard that is analyzed each day to evaluate instrument performance at or below the minimum reporting limit (MRL).

**Surrogate Standard (SS) / Surrogate Analyte (SUR)** - is a pure compound with properties similar to the analytes of interest, which is highly unlikely to be found in any field sample, that is added to the field samples, calibration standards, blanks and quality control standards before sample preparation. The SS is used to evaluate the efficiency of the sample preparation process.



**ANALYSIS REPORT**

Prepared by:

Eurofins Lancaster Laboratories Environmental  
2425 New Holland Pike  
Lancaster, PA 17601

Prepared for:

Eurofins QC Laboratories  
702 Electronic Drive  
Horsham PA 19044

Report Date: June 27, 2019 15:25

**Project: L7124682**Account #: 26093  
Group Number: 2049280  
State of Sample Origin: NJ

Electronic Copy To Eurofins QC Laboratories

Attn: Nicki Smith

**SAMPLE INFORMATION**Client Sample Description

L7124682-1 Drinking Water

Sample Collection  
Date/Time

06/17/2019 09:00

ELLE#

1082496

The specific methodologies used in obtaining the enclosed analytical results are indicated on the Laboratory Sample Analysis Record.

Respectfully Submitted,

Wendy A. Kozma  
Principal Specialist Group Leader

To view our laboratory's current scopes of accreditation please go to <https://www.eurofinsus.com/environment-testing/laboratories/eurofins-lancaster-laboratories-environmental/certifications-and-accreditations-eurofins-lancaster-laboratories-environmental/>. Historical copies may be requested through your project manager.

**Sample Description:** L7124682-1 Drinking Water  
KITCHEN SINK

**Eurofins QC Laboratories**  
ELLE Sample #: PW 1082496  
ELLE Group #: 2049280  
Matrix: Drinking Water

**Project Name:** L7124682

**Submittal Date/Time:** 06/17/2019 19:15  
**Collection Date/Time:** 06/17/2019 09:00

CAT No.	Analysis Name	CAS Number	Result	Method Detection Limit*	Limit of Quantitation	MCL	Dilution Factor
<b>GC/MS Volatiles</b>							
	<b>EPA 524.2</b>		<b>ug/l</b>	<b>ug/l</b>	<b>ug/l</b>	<b>ug/l</b>	
03648	Bromodichloromethane	75-27-4	9.8	0.1	0.5		1
03648	Bromoform	75-25-2	N.D.	0.2	0.5		1
03648	Chloroform	67-66-3	43	0.1	0.5		1
03648	Dibromochloromethane	124-48-1	2.6	0.1	0.5		1
<b>Metals</b>							
	<b>EPA 200.7 rev 4.4</b>		<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	
01750	Calcium	7440-70-2	27.4	0.0333	0.505		1
	<b>EPA 200.8 rev 5.4</b>		<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	
06033	Copper	7440-50-8	0.0321	0.0099	0.0101	1.3	1
The action level for copper in the lead and copper rule is 1.3 mg/l.							
06035	Lead	7439-92-1	N.D.	0.00067	0.0010	.015	1
The Lead and Copper Rule establishes a 15 ppb (0.015 mg/l) lead action limit for public water systems. This is based on a 1 liter sample size. The EPA recommends a limit of 20 ppb (0.02 mg/l) lead in school systems, based on a 250 ml sample size.							
<b>Wet Chemistry</b>							
	<b>SM 2320 B-2011</b>		<b>mg/l as CaCO3</b>	<b>mg/l as CaCO3</b>	<b>mg/l as CaCO3</b>	<b>mg/l as CaCO3</b>	
12150	Total Alkalinity to pH 4.5	n.a.	44.8	2.6	8.0		1
	<b>SM 2540 C-2011</b>		<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	<b>mg/l</b>	
00212	Total Dissolved Solids	n.a.	151	10.0	30.0	500	1
Total dissolved solids is a measure of residue remaining when a filtered water sample is evaporated. The Environmental Protection Agency (EPA) has established a secondary guideline of 500 mg/l total dissolved solids for drinking water.							

### Sample Comments

State of New Jersey Lab Certification No. PA011

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
03648	VOCs- 25ml Water by 524.2	EPA 524.2	1	K191762AA	06/26/2019 04:01	Hu Yang	1
01750	Calcium	EPA 200.7 rev 4.4	1	191700528101	06/19/2019 11:17	Kevin Litwa	1
06033	Copper	EPA 200.8 rev 5.4	1	191700605102A	06/21/2019 18:30	Bradley M Berlot	1
06035	Lead	EPA 200.8 rev 5.4	1	191700605102A	06/21/2019 18:30	Bradley M Berlot	1
05281	ICP Undigested Prep	EPA 200.7 rev 4.4	1	191700528101	06/19/2019 08:42	James L Mertz	1
06051	ICP-MS Undigested Prep	EPA 200.8 rev 5.4	1	191700605102	06/19/2019 10:30	Denise L Trimby	1
12150	Total Alkalinity to pH 4.5	SM 2320 B-2011	1	19170005202A	06/19/2019 20:39	Jeremy L Bolf	1
00212	Total Dissolved Solids	SM 2540 C-2011	1	19171921201A	06/20/2019 13:54	Angelica Cintron	1

\*=This limit was used in the evaluation of the final result  
Shaded result = The results or reporting limit exceeded the client-provided MCL.

2049200

EUROFINS QC, LLC  
702 Electronic Drive  
Horsham, PA 19044  
Contact: Nicki Smith x3360  
Phone: 215-355-3900  
FAX: 215-392-0626

EUROFINS QC, INC.  
LANCASTER (ELLE) CHAIN OF CUSTODY  
Jun 17 2019, 02:38 pm



PWSID:

Sample ID	Analysis	Number of Containers	Sampled Date and Time	Tier
-----------	----------	----------------------	-----------------------	------

State: NJ	Total	H2SO4	HCL	AscAc	HN03	NaOH	ZnAc	Unpre	Bact	Nathio	Other
	6										

L7124682-1 KITCHEN SINK  
COMM: SEE L7135421-2 TB

06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											
06/28/19	WATER											

524.2 THMS  
CA  
CU  
MO ALK  
PB  
TDS

Moisture? \_\_\_\_\_  
E-Account Number: 26093 TOWNSHIP OF HOPEWELL CS REP: INACTIVE  
Package Type:

Relinquished By	Date	Time
<i>CC</i>	6/17/19	1520
/		

Received By	Date	Time
<i>GT9</i>	6/17/19	1520
/		
<i>KA</i>	6/17/19	1515

Comments:

2049200

EQC Picksheet: P7124682

Eurofins QC, LLC Cust: W01628 STONY BROOK  
Sched: 54165

STEVEN WILFING  
STONY BROOK ELEMENTARY SCHOOL  
20 STEPHENSON ROAD

PENNINGTON, NJ 08534  
(609)737-4006 x6001

Expected: MONDAY 06/03/19 - 06/30/19

Project Name: STONY BROOK ELEMENTARY SCHOOL

Start Date: 05/30/18 Stop Date:

Comments/Schedule Details:

SAMPLES MUST BE COLLECTED ON MONDAY OR  
THURSDAY BETWEEN 9AM-4PM \* SUBMIT ONE QT  
UNPRES, 1/2 NITRIC, 3 ASC VIALS, HAA  
JAR, BACTI

Route: 6 SUE HUGHES

PWSID:

P  
S  
E  
U  
D  
O  
e  
c  
o  
H  
P  
C

7124682-1 KITCHEN SINK  
05-SAMP FLD, 524.2 THMS, CA, COLI/E COLI COL P/A, CU, FLD TEMP C, HAA, METAL PREP, MO ALK, PB, PH  
FLD, TDS



FIELD WORK CODE: 05-5-ADP

- LAB USE ONLY
- # \_\_\_\_\_ Ascorbic/HCL Vials \_\_\_\_\_ HCL Vials
  - # \_\_\_\_\_ NA2S2O3 \_\_\_\_\_
  - # \_\_\_\_\_ NaOH/Zn acetate pH \_\_\_\_\_
  - # \_\_\_\_\_ HNO3 pH \_\_\_\_\_
  - # \_\_\_\_\_ H2SO4 pH \_\_\_\_\_
  - # \_\_\_\_\_ NaOH pH \_\_\_\_\_
  - # \_\_\_\_\_ Unpreserved \_\_\_\_\_
  - # \_\_\_\_\_ HCL \_\_\_\_\_
  - # \_\_\_\_\_ NH4CL \_\_\_\_\_
  - # \_\_\_\_\_ MEOH \_\_\_\_\_
  - # \_\_\_\_\_ Na2SO3/HCL \_\_\_\_\_
  - # \_\_\_\_\_ DI Water \_\_\_\_\_

Collection Date	Collection Time Total (Milliary)	# Bottles	Field Tests By:			Free Cl2 mg/L	pH/Temp C	BPE2 YES/NO	Total CL2 mg/L
06/17/19	0900	8				0.00			7.89 / 20.9

Cooler ID:

Sample Collected By	Circle One Client	Initials	Date	Time	Received By	Date	Time	Temp	Iced Y/N	Site	Initials
Sue Hughes	EQC	SEH	06/17/19	1305	Bruno	06/17/19	1305	1.6c	Y	EAC	SEH
					Kan	06/17/19	1915	2.1	Y	ELCE	KA

Required TAT: Standard \_\_\_/Rush \_\_\_ # Days \_\_\_

Comments (reporting, methods, etc)  
 TP  
 FRTS SET 061719  
 SET 5/17

Hazardous Y/N

M: 09:00-16:00 T: - W: - Th: 09:00-16:00 F: - St - Sn: -  
 PM: - T: - W: - Th: - F: - St: - Sn: -  
 Printed: 06/22/19 GPS X: -



Group Number(s):

Client: EQCL

20A9200

**Delivery and Receipt Information**

Delivery Method: QC Labs      Arrival Timestamp: 06/17/2019 19:15  
 Number of Packages: 1      Number of Projects: 8

**Arrival Condition Summary**

Shipping Container Sealed:	Yes	Sample IDs on COC match Containers:	Yes
Custody Seal Present:	Yes	Sample Date/Times match COC:	Yes
Custody Seal Intact:	Yes	VOA Vial Headspace $\geq$ 6mm:	No
Samples Chilled:	Yes	Total Trip Blank Qty:	0
Paperwork Enclosed:	Yes	Air Quality Samples Present:	No
Samples Intact:	Yes		
Missing Samples:	No		
Extra Samples:	No		
Discrepancy in Container Qty on COC:	No		

Unpacked by Katherine Metzger (2241) at 21:51 on 06/17/2019

**Samples Chilled Details**

Thermometer Types:      DT = Digital (Temp. Bottle)      IR = Infrared (Surface Temp)      All Temperatures in °C.

Cooler #	Thermometer ID	Corrected Temp	Therm. Type	Ice Type	Ice Present?	Ice Container	Elevated Temp?
1	DT42-03	2.1	DT	Wet	Y	Bagged	N



# Explanation of Symbols and Abbreviations

The following defines common symbols and abbreviations used in reporting technical data:

<b>BMQL</b>	Below Minimum Quantitation Level	<b>mL</b>	milliliter(s)
<b>C</b>	degrees Celsius	<b>MPN</b>	Most Probable Number
<b>cfu</b>	colony forming units	<b>N.D.</b>	non-detect
<b>CP Units</b>	cobalt-chloroplatinate units	<b>ng</b>	nanogram(s)
<b>F</b>	degrees Fahrenheit	<b>NTU</b>	nephelometric turbidity units
<b>g</b>	gram(s)	<b>pg/L</b>	picogram/liter
<b>IU</b>	International Units	<b>RL</b>	Reporting Limit
<b>kg</b>	kilogram(s)	<b>TNTC</b>	Too Numerous To Count
<b>L</b>	liter(s)	<b>µg</b>	microgram(s)
<b>lb.</b>	pound(s)	<b>µL</b>	microliter(s)
<b>m3</b>	cubic meter(s)	<b>umhos/cm</b>	micromhos/cm
<b>meq</b>	milliequivalents	<b>MCL</b>	Maximum Contamination Limit
<b>mg</b>	milligram(s)		
<b>&lt;</b>	less than		
<b>&gt;</b>	greater than		
<b>ppm</b>	parts per million - One ppm is equivalent to one milligram per kilogram (mg/kg) or one gram per million grams. For aqueous liquids, ppm is usually taken to be equivalent to milligrams per liter (mg/l), because one liter of water has a weight very close to a kilogram. For gases or vapors, one ppm is equivalent to one microliter per liter of gas.		
<b>ppb</b>	parts per billion		
<b>Dry weight basis</b>	Results printed under this heading have been adjusted for moisture content. This increases the analyte weight concentration to approximate the value present in a similar sample without moisture. All other results are reported on an as-received basis.		

**Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.**

Measurement uncertainty values, as applicable, are available upon request.

Tests results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" are not performed within 15 minutes.

**WARRANTY AND LIMITS OF LIABILITY** - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. THE FOREGOING EXPRESS WARRANTY IS EXCLUSIVE AND IS GIVEN IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED. WE DISCLAIM ANY OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING A WARRANTY OF FITNESS FOR PARTICULAR PURPOSE AND WARRANTY OF MERCHANTABILITY. IN NO EVENT SHALL EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL, LLC BE LIABLE FOR INDIRECT, SPECIAL, CONSEQUENTIAL, OR INCIDENTAL DAMAGES INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF PROFIT OR GOODWILL REGARDLESS OF (A) THE NEGLIGENCE (EITHER SOLE OR CONCURRENT) OF EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL AND (B) WHETHER EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL HAS BEEN INFORMED OF THE POSSIBILITY OF SUCH DAMAGES. We accept no legal responsibility for the purposes for which the client uses the test results. No purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.

# Data Qualifiers

<b>Qualifier</b>	<b>Definition</b>
C	Result confirmed by reanalysis
D1	Indicates for dual column analyses that the result is reported from column 1
D2	Indicates for dual column analyses that the result is reported from column 2
E	Concentration exceeds the calibration range
K1	Initial Calibration Blank is above the QC limit and the sample result is ND
K2	Continuing Calibration Blank is above the QC limit and the sample result is ND
K3	Initial Calibration Verification is above the QC limit and the sample result is ND
K4	Continuing Calibration Verification is above the QC limit and the sample result is ND
J (or G, I, X)	Estimated value $\geq$ the Method Detection Limit (MDL or DL) and $<$ the Limit of Quantitation (LOQ or RL)
P	Concentration difference between the primary and confirmation column $>40\%$ . The lower result is reported.
P^	Concentration difference between the primary and confirmation column $>40\%$ . The higher result is reported.
U	Analyte was not detected at the value indicated
V	Concentration difference between the primary and confirmation column $>100\%$ . The reporting limit is raised due to this disparity and evident interference.
W	The dissolved oxygen uptake for the unseeded blank is greater than 0.20 mg/L.
Z	Laboratory Defined - see analysis report
B	Detection in the Blank
Q0	LCS/LCSD Low
Q1	LCS/LCSD High
Q2	MS/MSD Low
Q3	MS/MSD High
Q7	LCS/LCSD RPD
Q8	DUP RPD
Q9	MS/MSD RPD

Additional Organic and Inorganic CLP qualifiers may be used with Form 1 reports as defined by the CLP methods. Qualifiers specific to Dioxin/Furans and PCB Congeners are detailed on the individual Analysis Report.